





RC-1000 and RC-2000 Programmable Communicating Thermostat

ENERGY STAR

User's Guide

Contents

About your thermostat	
About your thermostat	1
Getting to know your thermostat's controls	2
Getting to know your thermostat's display (Advanced Display) Filter Reminder	4
Getting to know your thermostat's display (Simplified Display)	6
Changing the desired temperature settings	7
Changing the thermostat mode	
About the fan and hold settings	9
About the hold settings	10
Setting the time and date	11
Modifying the program schedule	12
Changing the desired humidity setting (RC-2000)	16
Display the runtime graph of air conditioning and heating usage	17

About your thermostat

Thank you for purchasing your new Omnistat2 electronic communicating thermostat. Your thermostat will provide you with comfort, convenience, and energy savings for years to come.

The Omnistat2 is a precision digital thermostat. It has the capability of being controlled both locally and remotely. It offers stand alone operation, programmability, and communications with automation systems, utility control systems, and personal computers.

Please take a few moments to become familiar with all of the features of your new thermostat by reviewing this guide. A complete Omnistat2 Owner's Manual can be downloaded from our web site at www.homeauto.com.


Features:

- Digitally precise temperature control
- 7 day programmable
- · Multicolor backlight, user defined color
- Proximity/motion detector, screen lights up when approached
- · Vacation mode
- · Easy to navigate menus
- · Communicates with automation systems, utility control systems, and personal computers
- Displays outdoor temperature
- Graphical display of HVAC usage, by week
- · Filter reminder
- · Large graphical display
- Learns the patterns of your house and uses smart control to apply maximum comfort with efficiency
- Automatic heat/cool changeover
- Fan cycle mode
- Humidity sensing¹
- Humidifier control¹
- Dehumidifier control¹

¹ Only available on the RC-2000


Getting to know your thermostat's controls

To take advantage of all the benefits and features offered by your new thermostat, we recommend that you start by becoming familiar with its controls.



Getting to know your thermostat's controls

The following icons are used throughout this guide:



Adjusting the contrast of the thermostat display:

To adjust the contrast of the thermostat display press and hold [FAN] while turning the Scroll Wheel:

790	Press and hold [FAN].	
•	While pressing [FAN], turn the Scroll Wheel to adjust the contrast.	
	When complete, release [FAN].	

Adjusting the color of the thermostat display:

To adjust the color of the thermostat display press and hold [HOLD] while turning the Scroll Wheel:


300	Press and hold [HOLD].
•	While pressing [HOLD], turn the Scroll Wheel to adjust the color.
000	When complete, release [HOLD].

BACKLIGHT

Color: 25
Brightness: 10
Status: Auto

Getting to know your thermostat's display (Advanced Display)

The following graphics will be displayed on the Home Page when using the Advanced Display:



Filter Reminder

Your thermostat logs the amount of time your heating and cooling system has been running and gives you a reminder when it's time to replace your filter. "Change Filter" will be displayed on the Message Bar when it is time to change your filter.



Press the Scroll Wheel twice to clear the change filter reminder. Don't forget to change your filter!


Getting to know your thermostat's display (Advanced Display)

(1)	Temperature: Displays the current indoor temperature.
(2)	Cool Setting: Displays the desired cool setting.
(3)	Heat Setting: Displays the desired heat setting.
(4)	Thermostat Mode: Displays the current system mode: Off, Heat, Cool, Auto, or EM Heat (Emergency Heat for heat pump systems)
(5)	Status Indicators:
	► Cool 1 st stage of air conditioning system is running
	► Heat 1 st stage of heating system is running
	► Cool 1 st and 2 nd stage of air conditioning system is running
	► ► Heat 1 st and 2 nd stage of heating system is running
	Note: The Status Indicators may flash to indicate a start up delay for equipment protection. After a few minutes, the compressor will start and the Status Indicators will stop flashing.
(6)	Message Bar: The message bar displays messages that you enable. If more than one message type is enabled, the message bar will displat the first message for 4 seconds, and then the next message is displayed. On the advanced display, the available message types are as follows:
	☐ Date and Time ☐ Outdoor Status (outdoor temperature and/or outdoor humidity) ☐ Filter Reminder (time to change the filter) ☐ Energy Status ☐ Energy Messages
(7)	Hold Setting: Displays the current hold setting: Off, On, or Vacation
(8)	Fan Setting: Displays the current fan mode: Auto, On, or Cycle
9)	Relative Humidity: Displays the current relative humidity (RC-2000 only).

(10) Period Indicator: Morn, Day, Eve, or Night is displayed when scheduled temperature changes are made by the thermostat programs.

Getting to know your thermostat's display (Simplified Display)


The following graphics will be displayed on the Home Page when using the Simplified Display:



- (1) Temperature: Displays the current indoor temperature.
- (2) Thermostat Mode: Displays the current mode: Heat or Cool. If the thermostat is in Off mode, this area is blank.
- (3) Temperature Setting: Displays the desired temperature setting for the current thermostat mode (the mode that is displayed directly above this setting). If the thermostat is in **Off** mode, this area is blank.
- (4) Status Indicators:
 - ► Cool 1st stage of air conditioning system is running
 - ► Heat 1st stage of heating system is running
 - ► Cool 1st and 2nd stage of air conditioning system is running
 - ► Heat 1st and 2nd stage of heating system is running
- (5) Time: The current time of day is displayed.

Changing the desired temperature settings


To change the desired temperature setting, simply turn the Scroll Wheel. With the first turn of the Scroll Wheel, the Temperature Settings Page is displayed:



Changing the thermostat mode

MODE

To change the thermostat mode, press [MODE]. When first pressed, the Mode Setting Page is displayed:




- > In Off mode, the heating and air conditioning systems are both off and do not respond to changes in the temperature settings.
- > In *Heat* mode, the heating system responds to maintain your desired heating temperature setting.
- In Cool mode, the air conditioning system responds to maintain your desired cooling temperature setting.
- > In *Auto* mode, your thermostat will automatically switch between heat and cool to maintain your desired heating and cooling temperature settings.
- In *Emergency Heat* mode (for heat pumps with auxiliary heat) the thermostat will turn off the heat pump and use the auxiliary heating to maintain the heating temperature setting. This mode should only be used if the heat pump is malfunctioning, because the auxiliary heat costs more to operate than the heat pump.

About the fan and hold settings

FAN


To change the fan setting, press [FAN]. When first pressed, the Fan Setting Page is displayed:



- In Fan Auto mode, the fan runs only when the system calls for heating or cooling.
- ➤ In Fan On mode, the fan runs continuously.
- ➤ In Fan Cycle mode, the fan is cycled on and off every 10 minutes to circulate the air

HOLD

To change the hold setting, press [HOLD]. When first pressed, the Hold Setting Page is displayed:




About the hold settings

In Hold mode, the thermostat will not change the desired temperature settings by program schedule or remote system.


- > In Hold Off mode, the thermostat responds to program schedule and remote system temperature setting changes.
- In *Hold On* mode, the thermostat ignores program schedule and remote system temperature setting changes.
- In *Hold Vacation* mode, the thermostat ignores program schedule and remote system temperature setting changes for the duration of your scheduled time away.

When Hold Vacation is selected, you are prompted for heat and cool settings and the number of days that it will hold those settings.



Setting the time and date

To set or change the current time and date, press and hold [MODE] for 5 seconds:





-) Set the current hour
- 2) Set the current minutes
- 3) Set AM or PM
- 4) Set the month
- 5) Set the day
- 6) Set the year

9	Turn the Scroll Wheel to adjust each item for the time and date.
En .	After each item is set, press the Scroll Wheel or [Next] to adjust the next item.
$\bigcirc \bullet \bigcirc$	After the time and date has been set, press [Ok] to save it to memory.
• • •	Press [Cancel] to discard changes.


Your new thermostat has been preprogrammed with energy saving settings according to the ENERGY STAR® program. You may modify the times and temperature settings to maximize energy savings and comfort based on your lifestyle.

Your thermostat may be programmed to adjust the heating and cooling temperature settings up to 4 times per day, with different times and temperature settings for every day of the week (Monday – Sunday). You may also modify the schedule for a day, and then copy that schedule to other days. This is especially beneficial if you have the same schedule on weekdays. You can modify a single day's schedule and then copy it to the remaining weekdays.

Main Menu



To modify the existing program schedule, press the Scroll Wheel once to display the Main Menu.



	Monday	,	
	TIME	HEAT	COOL
MORNING	6:00AM	70	78
DAY	8:00AM	62	85
EVENING	6:00PM	70	78
NIGHT	10:00PM	62	82
Cancel	Ok		Сору



Turn the Scroll Wheel to adjust the time for the selected period on the respective day. This is the time in which the selected period starts and the previous period ends.

- The time is increased and decreased in 15 minute increments.
- To disable a period, set it and the next period to the same time.

The time schedules above are preprogrammed into your thermostat for every day of the week.


The 4 time periods for each day of the week are as follows:

MORNING	This is the time in which you typically awaken in the morning, along the desired temperature settings that will remain until you leave your home for the day.
DAY	This is the time in which you leave your home for the day, along with the desired temperature settings that will remain until you return home in the evening.
EVENING	This is the time in which you return home in the evening, along with the desired temperature settings that will remain until you go to bed at night.
NIGHT	This is the time in which you go to bed at night, along with the desired temperature settings that will remain until you awake the next morning.



When the desired time is displayed for the selected period, press the Scroll Wheel to highlight the Heat temperature setting for the selected period on the respective day.

	Monday		
	TIME	HEAT	COOL
MORNING	6:00AM	70	78
DAY	8:00AM	62	85
EVENING	6:00PM	70	78
NIGHT	10:00PM	62	82
Cancel	Ok		Сору



9	Turn the Scroll Wheel to adjust the desired Cool Settings that the thermostat will maintain for the selected period on the respective day.
(F)	When the desired Cool Setting is displayed for the selected period, press the Scroll Wheel to highlight the time for the next period on the respective day.

	Monday	•	
	TIME	HEAT	COOL
MORNING	6:00AM	70	78
DAY	8:00AM	62	85
EVENING	6:00PM	70	78
NIGHT	10:00PM	62	82
Cancel	Ok		Сору

	Monday	,	
	TIME	HEAT	COOL
MORNING	6:00AM	70	78
DAY	8:00AM	62	85
EVENING	6:00PM	70	78
NIGHT	10:00PM	62	82
Cancel	Ok		Сору


Make any desired modifications for the selected period.		
$\bigcirc \bullet \bigcirc$	When the schedule for each period of the respective day is complete, press [Ok] to save the changes.	
	When the schedule for each period of the respective day is complete, press [Copy] to save the changes and copy the schedule to other days in the week.	
$\bullet \circ \circ$	Press [Cancel] to discard changes.	

Notes:

- At any time, you can undo changes made to the current schedule on the respective day by pressing [Cancel].
 - Select a day from the list of days and modify the program schedule for that day, OR
 - o Press [Back] twice, to return to the Home Page
- When all of the modifications are complete, you can save the schedule for the respective day by pressing [Ok].
 - Select a different day from the list of days and modify the program schedule for that day, OR
 - o Press [Back] twice, to return to the Home Page
- When all of the modifications are complete, you can save and copy the schedule for the respective day to any of the other days in a week by pressing [Copy].

Copying a time schedule to other days

You may copy the program schedule from any given day, and copy it to any other day(s) in a week. After the schedule for the respective day has been completed, press [Copy].




•	Turn the Scroll Wheel to highlight the desired day(s).
(Fe)	Press the Scroll Wheel to check the box next to the day(s) in which the current schedule will be used.
$\bigcirc \bullet \bigcirc$	When the desired days have been selected, press [Ok] to save the schedule tor each of the checked days.
• • • •	Press [Cancel] to discard changes.


Changing the desired humidity settings (RC-2000)

Main Menu



To change the desired temperature setting, press the Scroll Wheel once to display the Main Menu.





HUMII	DITY TARG	<u>ETS</u>
Humidit	y Setpoint:	25 %RH
Dehumid	y Setpoint:	55 %RH
Cancel	Ok	Next


9	Turn the Scroll Wheel to adjust the desired humidity and dehumidify setting.
En .	Press the Scroll Wheel or [Next] to switch between the humidity and dehumidify setpoints.
$\bigcirc \bullet \bigcirc$	When humidity settings have been set, press [Ok] and then [Back] to return to the Home Page.
\bigcirc	Press [Cancel] two times, to discard changes and return to the Home Page.


Display the runtime graph of air conditioning and heating usage


Main Menu




To view a System Runtime graph of air conditioning and heating usage over the past 4 weeks, press the Scroll Wheel once to display the Main Menu.









System Runtime Bar Graph 0-3: This area displays the bar values and hours that the air conditioning and/or heating system operated in the current week (Week 0) and in the three previous weeks (Weeks 1-3), respectively.







This thermostat has been tested and found to comply with the requirements of the European Union for Electromagnetic Interference, Electromagnetic Immunity and Safety under the applicable EMI and Low Voltage Directives and Standards.

As an EPA ENERGY STAR® Partner, Home Automation, Inc. has determined that this thermostat meets the ENERGY STAR guidelines for energy efficiency.

This thermostat has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules.

This product generates and can radiate radio frequency energy. Due to its low power design, it is unlikely to interfere with radio and TV communications. If it is suspected of doing so, the user is encouraged to try to correct the problem by reorienting the receiver's antenna, moving the receiver away from the product, or consulting an experienced radio/TV technician for help.

